



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Chemical Examination of Water

954

15/9/26

To
Ravinder Kaur H.M.
Guru Ramdass Convent School
9-Z, Sri Ganganagar

Reference No : 00. Dated 08/09/2026

Date of Receipt 08/09/2026

District : GANGANAGAR

Sample Taker : Your Self

Source Location	Permissible Value as per B.I.S. 10500:2012		Tank
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	Ramdass Convent School 9-Z
Village/Town			Ganganagar (MCI)
Gram Panchayat			
Date of Collection			08/09/2026
Date of Examination			14/09/2026
Sample No.			553

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.2
Turbidity (NTU)	1	5	4
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	---	---	---
Total Alkalinity	200	600	190
Total Hardness (as CaCO ₃)	200	600	240
Calcium (as Ca)	75	200	36
Magnesium (as Mg)	30	100	36.6
Chlorides as Cl	250	1000	60
Sulphates as SO ₄	200	400	---
Nitrate as (NO ₃)	45	45	7
Fluoride	1.0	1.5	0.38
Total Dissolved Solids	500	2000	530
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Note : (1) Samples are not collected by laboratory.
(2) Report is not valid for water quality legal purposes.

Remarks : Water is Potable (P)/Unpotable (U)
No. Lab. Tech. (chem)/2026-27/553

Ravinder Kaur
H.M.
Guru Ramdass Convent School
9-Z, Sri Ganganagar -335001

4071
(प्रभा बरवाल)
कनिष्ठ रसायनज्ञ
जन. प्र. अभि. विभाग
जिला प्र. प्र. कार्यालय, गंगानगर
प. प्र. प्र. कोड नं. 10484



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Bacteriological Examination of Water

Date: 10/09/2026

To,
Head Master,
Guru ramdass Convent School,
9 Z Sri Ganganagar.

District : GANGANAGAR
Block : GANGANAGAR
Sample Taker : Self

Reference No : 00, Dated : 08/09/2026
Date of Receipt : 08/09/2026
Date of Exam : 08/09/2026

Sample No.	Date & Time of Collection	Gram Panchayat	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
1414	08/09/2026	9 Z	9 Z	Tank	Tank In Guru ramdass Convent School, 9 Z Sri Ganga	Nil	Nil	Satisfactory	Potable

Note : (1) Samples are not collected by laboratory.
(2) Report is not valid for water quality legal purposes.

(Signature)
(Junior Chemist)
Public Health Engineering Department, Ganganagar
जन स्वा. अभि. विभाग
जिला-प्रयोगशाला श्रीगंगानगर
डि.डो.ओ.कोड नं. : 10484

Ravinder kaur
H.M.
Guru Ramdass Convent School
a-7 Sri Ganganagar -335001